



23 East Main Street • P.O. Box 879 • Vernal, UT 84078 • 801-789-3714

RECEIVED

APR 29 1985

WATER RIGHTS SALT LAKE

## **MEMORANDUM**

TO: Richard Hall, Distribution Engineer FROM: Blake Wahlen, Asst. Area Engineer SUBJECT: Deep Creek Distribution System

DATE: April 25, 1985

A field review of the Deep Creek Distribution system was made with the following in attendance:

Charmin Justice, Commissioner Arthur McKee, Chairman Blake Wahlen, Vernal Office

The major diversion structures and measuring devices, that were accessable, were visited. It is recommended that the State Engineer order the following:

- 1. Installation of diversion works and measuring device on the Orlando Cook ditch. A = A
- 2. The Darvel Cook measuring device be set closer to the diversion structure, so that the commissioner can regulate the water properly. And, a key be provided to the commissioner to have access to both the measuring device and diversion works.
- 3. Installation of a measuring device and adequate diversion works at the Wilmer Parrish reservoir. And, that the reservoir be filed on properly through our office.
- 4. Installation of a measuring device on the Arben Wilkerson ditch (East Mosby Ditch).
- 5. The Parshall flume approach channel on the Lance Luck #1 ditch be cleaned and properly maintained.
- 6. Installation of the diversion works for the Robert Justice ditch.
- 7. All unpaid assessments be collected.

It is further recommended that the above changes be made in 60 days, allowing the commissioner to distribute the water, and make future assessments accurate.